

VIA E-MAIL



June 27, 2011

Roger Aisladie
Gripple, Inc.
1611 Emily Avenue
Aurora, IL 60502

Re: Gripple Duct Trapeze

Dear Mr. Aisladie:

The SMACNA Testing & Research Institute (STRI) verifies that the Gripple Purpose-Made Single Channel Suspension System for Rectangular Duct, as submitted and tested, to be an acceptable alternative to the duct hanger systems prescribed in the SMACNA/ANSI HVAC Duct Construction Standards (HVAC-DCS) 3rd Edition 2005, Chapter 5, Figure 5-5 Strap Hangers for ducts not exceeding maximum width of 60" as noted.

Professionally yours,
SMACNA Testing & Research Institute

A handwritten signature in black ink that reads "Eli P. Howard, III".

Eli P. Howard, III
Executive Director

Enclosures